

Energy Consumption and Greenhouse Gas Emissions Reporting - for 2018

Confirm consecutive 12-mth period (mth-yr to mth-yr)	Jan/2018 - Dec/2018
Sector	Municipal Service Board
Agency Sub-sector	Municipal
Organization Name	Elgin Area Primary Water Supply System Joint Board of Management
Operation Name	Elgin Area Water Treatment Plant
Operation Type	Facilities related to the treatment of water
Address	43665 Dexter Line
City	Central Elgin
Postal Code	N5L 1J4
Avg hrs/wk	168
Annual Flow (ML)	16132.9
Electricity Quantity	10,227,030.00
Electricity Unit	kWh
Natural Gas Quantity	238,033.00
Natural Gas Unit	Cubic Meter
GHG Emissions (Kg)	752,219.90
Energy Intensity (ekWh/Mega Litre)	790.73146
Comments	